

Certificate of Compliance


This is to certify that

EDGE ANALYTICAL, Inc.,
An Accredited Drinking Water Laboratory,
Certification number 046, has completed the analysis of

PURETAP WATER DISTILLERS LTD

“Steam Distilled Water”

on April 25, 2016, according to the CBWA Model Code testing requirements for bottled drinking water. All parameters were found to be in compliance with CBWA’s published Standard of Quality limits for bottled water.



Lawrence J. Henderson, PhD
Director of Laboratories

The signature of Lawrence J. Henderson, PhD, is written in black ink above a horizontal line. Below the line, his name and title are printed in a blue, sans-serif font.



Burlington, WA	Corporate Laboratory (a)	1620 S Walnut St	Burlington, WA 98233	800.755.9295 • 360.757.1400
Bellingham, WA	Microbiology (b)	805 Orchard Dr Ste 4	Bellingham, WA 98225	360.715.1212
Portland, OR	Microbiology/Chemistry (c)	9150 SW Pioneer Ct Ste W	Wilsonville, OR 97070	503.682.7802
Corvallis, OR	Microbiology (d)	540 SW Third Street	Corvallis, OR 97333	541.753.4946

April 25, 2016

Page 1 of 1

Mr. Mario Iorio
Puretap Water Distillers Ltd
950 Verbena Road
Mississauga, ON L5T 1T6
RE: 16-06521 - Steam Distilled Product

Dear Mr. Mario Iorio,

Your project: Steam Distilled Product, was received on Monday March 28, 2016.

All samples were analyzed within the accepted holding times, were appropriately preserved and were analyzed according to approved analytical protocols. The quality control data was within laboratory acceptance limits, unless specified in the QA reports.

If you have questions phone us at 800 755-9295.

Respectfully

Patrick Miller, MS
QA Officer

Enclosures: Data Report
QC Reports
Chain of Custody



Burlington, WA	Corporate Laboratory (a)	1620 S Walnut St	Burlington, WA 98233	800.755.9295 • 360.757.1400
Bellingham, WA	Microbiology (b)	805 Orchard Dr Ste 4	Bellingham, WA 98225	360.715.1212
Portland, OR	Microbiology/Chemistry (c)	9150 SW Pioneer Ct Ste W	Wilsonville, OR 97070	503.682.7802
Corvallis, OR	Microbiology (d)	540 SW Third Street	Corvallis, OR 97333	541.753.4946



BOTTLED WATER STANDARD OF QUALITY REPORT

Client Name: Puretap Water Distillers Ltd
 950 Verbena Road
 Mississauga, ON L5T 1T6

Reference Number: **16-06521**

Authorized by:

Pat Miller
 Patrick Miller, MS
 QA Officer

Project: Steam Distilled Product

Field ID:

Sample Description: Steam Distilled Water

Sampled By:

Sample Date: 03/28/2016

Lab Number: 15192

Report Date: 04/25/2016

Approved By: anp,bj,co,fm,hy,jaa,ljh,mcs,

Inorganic Chemicals (IOCs)

CAS ID#	COMPOUNDS	RESULT	SOQ	MRL	Units	Method	Lab	COMMENT
7440-36-0	ANTIMONY	ND	0.006	0.001	mg/L	200.8	a	
7440-38-2	ARSENIC	ND	0.010	0.001	mg/L	200.8	a	
7440-39-3	BARIUM	ND	1.0	0.001	mg/L	200.8	a	
7440-41-7	BERYLLIUM	ND	0.004	0.001	mg/L	200.8	a	
7440-43-9	CADMIUM	ND	0.005	0.001	mg/L	200.8	a	
7440-47-3	CHROMIUM	ND	0.05	0.005	mg/L	200.8	a	
16984-48-8	FLUORIDE	ND	1.0	0.10	mg/L	300.0	a	
7439-92-1	LEAD	ND	0.005	0.001	mg/L	200.8	a	
7439-97-6	MERCURY	ND	0.001	0.0002	mg/L	245.1	a	
7440-02-0	NICKEL	0.002	0.1	0.001	mg/L	200.8	a	
14797-55-8	NITRATE-N	ND	10	0.10	mg/L	300.0	a	
14797-65-0	NITRITE-N	ND	1.0	0.10	mg/L	300.0	a	
E-10128	TOTAL NITRATE/NITRITE	ND	10	0.10	mg/L	300.0	a	
7782-49-2	SELENIUM	ND	0.010	0.005	mg/L	200.8	a	
7440-28-0	THALLIUM	ND	0.002	0.001	mg/L	200.8	a	

Notation:

A Result of "ND" indicates that the compound was not detected above the Lab's Reporting Limit - MRL.

SOQ - Standard of Quality, maximum permissible level of a contaminant in water established by EPA, NPDWR or IBWA.

MRL - Method Reporting Limit.

An * in front of the parameter name indicates it is not NELAP accredited but it is accredited through WSDOH or USEPA Region 10.

These test results meet all the requirements of NELAC, unless otherwise stated in writing, and relate only to these samples. If you have any questions concerning this report contact us at the above phone number.

BOTTLED WATER STANDARD OF QUALITY REPORT

CAS ID#	COMPOUNDS	RESULT	SOQ	MRL	Units	Method	Lab	COMMENT
57-12-5	* CYANIDE, FREE	ND	0.1	0.010	mg/L	OIA-1677-DW	a	
7429-90-5	ALUMINUM	ND	0.2	0.010	mg/L	200.7	a	
16887-00-6	CHLORIDE	ND	250	0.1	mg/L	300.0	a	
7440-50-8	COPPER	0.007	1.0	0.005	mg/L	200.8	a	
7439-89-6	IRON	ND	0.3	0.050	mg/L	200.7	a	
7439-96-5	MANGANESE	ND	0.05	0.001	mg/L	200.8	a	
7440-22-4	SILVER	ND	0.025	0.010	mg/L	200.8	a	
14808-79-8	SULFATE	ND	250	0.2	mg/L	300.0	a	
E-10173	TOTAL DISSOLVED SOLIDS (TDS)	ND	500	10	mg/L	SM2540 C	a	
7440-66-6	ZINC	ND	5.0	0.005	mg/L	200.8	a	

Notation:

A Result of "ND" indicates that the compound was not detected above the Lab's Reporting Limit - MRL.

SOQ - Standard of Quality, maximum permissible level of a contaminant in water established by EPA, NPDWR or IBWA.

MRL - Method Reporting Limit .

An * in front of the parameter name indicates it is not NELAP accredited but it is accredited through WSDOH or USEPA Region 10.

These test results meet all the requirements of NELAC, unless otherwise stated in writing, and relate only to these samples.

BOTTLED WATER STANDARD OF QUALITY REPORT

Volatile Organic Chemicals (VOCs)

CAS ID#	COMPOUNDS	RESULT	SOQ	MRL	Units	Method	Lab	COMMENT
71-55-6	1,1,1 - TRICHLOROETHANE	ND	0.030	0.0004	mg/L	524.2	a	
79-00-5	1,1,2 - TRICHLOROETHANE	ND	0.003	0.0004	mg/L	524.2	a	
75-35-4	1,1 - DICHLOROETHYLENE	ND	0.002	0.0004	mg/L	524.2	a	
120-82-1	1,2,4 - TRICHLOROBENZENE	ND	0.009	0.0004	mg/L	524.2	a	
107-06-2	1,2 - DICHLOROETHANE	ND	0.002	0.0004	mg/L	524.2	a	
78-87-5	1,2 - DICHLOROPROPANE	ND	0.005	0.0004	mg/L	524.2	a	
71-43-2	BENZENE	ND	0.001	0.0004	mg/L	524.2	a	
56-23-5	CARBON TETRACHLORIDE	ND	0.002	0.0004	mg/L	524.2	a	
156-59-2	CIS - 1,2 - DICHLOROETHYLENE	ND	0.070	0.0004	mg/L	524.2	a	
156-60-5	TRANS - 1,2 - DICHLOROETHYLENE	ND	0.100	0.0004	mg/L	524.2	a	
100-41-4	ETHYLBENZENE	ND	0.0024	0.0004	mg/L	524.2	a	
75-09-2	METHYLENE CHLORIDE (DICHLOROMETHANE)	ND	0.003	0.0004	mg/L	524.2	a	
108-90-7	MONOCHLOROBENZENE	ND	0.050	0.0004	mg/L	524.2	a	
95-50-1	O - DICHLOROBENZENE	ND	0.200	0.0004	mg/L	524.2	a	
106-46-7	P - DICHLOROBENZENE	ND	0.005	0.0004	mg/L	524.2	a	
100-42-5	STYRENE	ND	0.100	0.0004	mg/L	524.2	a	
127-18-4	TETRACHLOROETHYLENE	ND	0.001	0.0004	mg/L	524.2	a	
108-88-3	TOLUENE	ND	0.024	0.0004	mg/L	524.2	a	
79-01-6	TRICHLOROETHYLENE	ND	0.001	0.0004	mg/L	524.2	a	
75-01-4	VINYL CHLORIDE	ND	0.002	0.0004	mg/L	524.2	a	
1330-20-7	XYLENES (TOTAL)	ND	0.300	0.0004	mg/L	524.2	a	
75-27-4	BROMODICHLOROMETHANE	ND		0.0004	mg/L	524.2	a	
124-48-1	CHLORODIBROMOMETHANE	ND		0.0004	mg/L	524.2	a	
67-66-3	CHLOROFORM	ND		0.0004	mg/L	524.2	a	
75-25-2	BROMOFORM	ND		0.0004	mg/L	524.2	a	
E-14471	TOTAL TRIHALOMETHANE	ND	0.010	0.0004	mg/L	524.2	a	
1634-04-4	METHYL TERT-BUTYL ETHER	ND	0.070	0.0004	mg/L	524.2	a	

Notation:

A Result of "ND" indicates that the compound was not detected above the Lab's Reporting Limit - MRL.

SOQ - Standard of Quality, maximum permissible level of a contaminant in water established by EPA, NPDR or IBWA.

MRL - Method Reporting Limit.

An * in front of the parameter name indicates it is not NELAP accredited but it is accredited through WSDOH or USEPA Region 10.

These test results meet all the requirements of NELAC, unless otherwise stated in writing, and relate only to these samples.

BOTTLED WATER STANDARD OF QUALITY REPORT

CAS ID#	COMPOUNDS	RESULT	SOQ	MRL	Units	Method	Lab	COMMENT
80-05-7	* BISPHENOL-A	ND		1	ug/L	525.2	a	qualitative analysis
93-72-1	2,4,5 - TP (SILVEX)	ND	0.010	0.0002	ug/L	515.4	a	
94-75-7	2,4 - D	ND	0.070	0.0001	ug/L	515.4	a	
15972-60-8	ALACHLOR	ND	0.002	0.0002	mg/L	525.2	a	
116-06-3	ALDICARB	ND	0.003	0.001	mg/L	531.2	a	
1646-88-4	ALDICARB SULFONE	ND	0.003	0.001	mg/L	531.2	a	
1646-87-3	ALDICARB SULFOXIDE	ND	0.004	0.001	mg/L	531.2	a	
1912-24-9	ATRAZINE	ND	0.003	0.0001	mg/L	525.2	a	
1563-66-2	CARBOFURAN	ND	0.040	0.0009	mg/L	531.2	a	
57-74-9	CHLORDANE	ND	0.0005	0.0002	mg/L	508.1	a	
75-99-0	DALAPON	ND	0.200	0.001	ug/L	515.4	a	
96-12-8	DIBROMOCHLOROPROPANE (DBCP)	ND	0.0002	0.00002	mg/L	504.1	a	
88-85-7	DINOSEB	ND	0.007	0.0002	ug/L	515.4	a	
72-20-8	ENDRIN	ND	0.002	0.00001	mg/L	525.2	a	
106-93-4	1,2 - DIBROMOETHANE (EDB)	ND	0.00005	0.00001	mg/L	504.1	a	
76-44-8	HEPTACHLOR	ND	0.0004	0.00004	mg/L	525.2	a	
1024-57-3	HEPTACHLOR EPOXIDE "B"	ND	0.0002	0.00002	mg/L	525.2	a	
58-89-9	LINDANE (BHC - GAMMA)	ND	0.0002	0.00002	mg/L	525.2	a	
72-43-5	METHOXYCHLOR	ND	0.040	0.0001	mg/L	525.2	a	
23135-22-0	OXAMYL (VYDATE)	ND	0.200	0.002	mg/L	531.2	a	
87-86-5	PENTACHLOROPHENOL	ND	0.001	0.00004	ug/L	515.4	a	
1918-02-1	PICLORAM	ND	0.190	0.0001	ug/L	515.4	a	
1336-36-3	POLYCHLORINATED BIPHENYLS (PCB)	ND	0.0005	0.0001	mg/L	508.1	a	
122-34-9	SIMAZINE	ND	0.004	0.00007	mg/L	525.2	a	
8001-35-2	TOXAPHENE	ND	0.003	0.001	mg/L	508.1	a	
41903-57-5	DIOXIN (2,3,7,8-TETRACHLORODIBEN;	ND	3E-8	5E-9	mg/L	1613		Analyzed by PACE_MN
85-00-7	DIQUAT	ND	0.020	0.0004	ug/L	549.2	a	
145-73-3	ENDOTHALL	ND	0.100	0.009	mg/L	548.1	a	
1071-83-6	GLYPHOSATE	ND	0.280	0.006	mg/L	547	a	
50-32-8	BENZO(A)PYRENE	ND	0.0002	0.00002	mg/L	525.2	a	
103-23-1	DI(2-ETHYLHEXYL)-ADIPATE	ND	0.400	0.0006	mg/L	525.2	a	
117-81-7	DI(2-ETHYLHEXYL)-PHTHALATE	ND	0.006	0.0006	mg/L	525.2	a	
118-74-1	HEXACHLOROBENZENE	ND	0.001	0.0001	mg/L	525.2	a	
77-47-4	HEXACHLOROCYCLO-PENTADIENE	ND	0.050	0.0001	mg/L	525.2	a	
E-10253	* PHENOLICS	ND	0.001	0.001	mg/L	420.4		Analyzed by NSF

Notation:

A Result of "ND" indicates that the compound was not detected above the Lab's Reporting Limit - MRL.

SOQ - Standard of Quality, maximum permissible level of a contaminant in water established by EPA, NPDWR or IBWA.

MRL - Method Reporting Limit .

An * in front of the parameter name indicates it is not NELAP accredited but it is accredited through WSDOH or USEPA Region 10.

These test results meet all the requirements of NELAC, unless otherwise stated in writing, and relate only to these samples.

BOTTLED WATER STANDARD OF QUALITY REPORT

Water Properties

CAS ID#	COMPOUNDS	RESULT	SOQ	MRL	Units	Method	Lab	COMMENT
E-11712	COLOUR	ND	5	5	Color Units	SM2120 B	a	pH: 6.5
E-10617	TURBIDITY	ND	0.5	0.10	NTU	180.1	a	
E-10139	HYDROGEN ION (pH)	6.28	5.0-8.5		pH Units	150.1	a	
E-11734	* ODOUR	ND	3	1	TON	SM2150	a	Temperature: 40.1

Notation:

A Result of "ND" indicates that the compound was not detected above the Lab's Reporting Limit - MRL.

SOQ - Standard of Quality, maximum permissible level of a contaminant in water established by EPA, NPDWR or IBWA.

MRL - Method Reporting Limit .

An * in front of the parameter name indicates it is not NELAP accredited but it is accredited through WSDOH or USEPA Region 10.

These test results meet all the requirements of NELAC, unless otherwise stated in writing, and relate only to these samples.

BOTTLED WATER STANDARD OF QUALITY REPORT

Disinfectants/DBP

CAS ID#	COMPOUNDS	RESULT	SOQ	MRL	Units	Method	Lab	COMMENT
NA	* HAA(5)	ND	0.060	0.001	mg/L	552.3	a	
15541-45-4	BROMATE	ND	0.010	0.001	mg/L	300.1	a	
10049-04-4	* CHLORINE DIOXIDE	ND	0.8	0.10	mg/L	SM4500-CIO2 I	a	Opn'd 3/28/16 1050
7758-19-2	* CHLORITE	ND	1.00	0.010	mg/L	300.1	a	
NA	* CHLOROAMINES TOTAL	ND	3.0	0.05	mg/L	SM4500-CI G	a	Opn'd 3/28/16 1050
7782-50-5	* FREE CHLORINE RESIDUAL	ND	0.1	0.05	mg/L	SM4500-CI G	a	Opn'd 3/28/16 1050

Notation:

A Result of "ND" indicates that the compound was not detected above the Lab's Reporting Limit - MRL.

SOQ - Standard of Quality, maximum permissible level of a contaminant in water established by EPA, NPDWR or IBWA.

MRL - Method Reporting Limit .

An * in front of the parameter name indicates it is not NELAP accredited but it is accredited through WSDOH or USEPA Region 10.

These test results meet all the requirements of NELAC, unless otherwise stated in writing, and relate only to these samples.

BOTTLED WATER STANDARD OF QUALITY REPORT

Radiological Contaminants

CAS ID#	COMPOUNDS	RESULT	SOQ	MRL	Units	Method	Lab	COMMENT
12587-46-1	GROSS ALPHA	ND	15	3	pCi/L	900.0		Analyzed by Pace
12587-47-2	GROSS BETA	ND	50	4	pCi/L	900.0		Analyzed by Pace

Notation:

A Result of "ND" indicates that the compound was not detected above the Lab's Reporting Limit - MRL.

SOQ - Standard of Quality, maximum permissible level of a contaminant in water established by EPA, NPDWR or IBWA.

MRL - Method Reporting Limit .

An * in front of the parameter name indicates it is not NELAP accredited but it is accredited through WSDOH or USEPA Region 10.

These test results meet all the requirements of NELAC, unless otherwise stated in writing, and relate only to these samples.



Burlington, WA *Corporate Laboratory (a)*
 1620 S Walnut St - Burlington, WA 98233 - 800.755.9295 • 360.757.1400
 Bellingham, WA *Microbiology (b)*
 805 Orchard Dr Ste 4 - Bellingham, WA 98225 - 360.715.1212

Portland, OR *Microbiology/Chemistry (c)*
 9150 SW Pioneer Ct Ste W - Wilsonville, OR 97070 - 503.682.7802
 Corvallis, OR *Microbiology/Chemistry (d)*
 540 SW Third Street - Corvallis, OR 97333 - 541.753.4946
 Bend, OR *Microbiology (e)*
 20332 Empire Blvd Ste 4 - Bend, OR 97701 - 541.639.8425



Data Report

Client Name: Puretap Water Distillers Ltd
 950 Verbena Road
 Mississauga, ON L5T 1T6


Reference Number: **16-06521**
 Project: Steam Distilled Product

Report Date: 4/25/16

Date Received: 3/28/16

Approved by: anp,bj

Authorized by:


 Patrick Miller, MS
 QA Officer

Sample Description: Steam Distilled Water										Sample Date: 3/28/16 9:00 am		
Lab Number: 15192		Sample Comment:								Collected By:		
CAS ID#	Parameter	Result	PQL	MDL	Units	DF	Method	Lab	Analyzed	Analyst	Batch	Comment
7440-70-2	CALCIUM	ND	1	0.009	mg/L	1.0	200.7	a	4/5/16	BJ	200.7_160405A	
E-11778	HARDNESS as Calcium Carbonate	ND	10	0.01	mg/L	1.0	200.7	a	4/5/16	BJ	200.7_160405A	
7439-95-4	MAGNESIUM	ND	1	0.001	mg/L	1.0	200.7	a	4/5/16	BJ	200.7_160405A	
7440-09-7	POTASSIUM	ND	1.0	0.1	mg/L	1.0	200.7	a	4/5/16	BJ	200.7_160405A	
7440-23-5	SODIUM	ND	0.50	0.05	mg/L	1.0	200.7	a	4/5/16	BJ	200.7_160405A	
E-10184	ELECTRICAL CONDUCTIVITY	ND	10		uS/cm	1.0	SM2510 B	a	3/28/16	MMH	EC_160328	

Notes:

ND = Not detected above the listed practical quantitation limit (PQL) or not above the Method Detection Limit (MDL), if requested.

PQL = Practical Quantitation Limit is the lowest level that can be achieved within specified limits of precision and accuracy during routine laboratory operating conditions.

D.F. - Dilution Factor

An * in front of the parameter name indicates it is not NELAP accredited but it is accredited through WSDOH or USEPA Region 10.

These test results meet all the requirements of NELAP, unless otherwise stated in writing, and relate only to these samples. Estimates of uncertainty are not included in this report. If this information is required please contact us at the phone number listed in the report header.

If you have any questions concerning this report contact us at the above phone number.



Burlington, WA	Corporate Laboratory (a)	1620 S Walnut St	Burlington, WA 98233	800.755.9295 • 360.757.1400
Bellingham, WA	Microbiology (b)	805 Orchard Dr Ste 4	Bellingham, WA 98225	360.715.1212
Portland, OR	Microbiology/Chemistry (c)	9150 SW Pioneer Ct Ste W	Wilsonville, OR 97070	503.682.7802
Corvallis, OR	Microbiology (d)	540 SW Third Street	Corvallis, OR 97333	541.753.4946

Washington State Department of Health WATER BACTERIOLOGICAL ANALYSIS


Client Name: Puretap Water Distillers Ltd
950 Verbena Road
Mississauga, ON L5T 1T6

Reference Number: 16-06521
Project: Steam Distilled Product

System Name:
System ID Number:
DOH Source Number:
Sample Type:
Sample Purpose: Investigative or Other
Sample Location: Steam Distilled Water
County:
Sampled By:
Sampler Phone:

Repeat Sample Number:
Lab Number: 046-15192
Field ID:
Date Collected: 3/28/16 09:00
Date Received: 3/28/16
Date Analyzed: 3/29/16 12:26
Report Date: 4/25/16
Comment:
Approved By: clc,ljh

Authorized by:


Patrick Miller, MS
QA Officer

DOH#	PARAMETER	RESULT	UNITS	Analyst	METHOD	Batch	COMMENT
1	TOTAL COLIFORM	Satisfactory, Coliforms Absent	per 100mL	bj	SM9223 B	M_160328B	
3	E. COLI	Absent	per 100mL		SM9223 B	M_160328B	

If the sample is unsatisfactory you can get information at the following health department websites or phone numbers:

- Island Co: <http://www.islandcounty.net/health/Envh/DrinkingWater/index.htm>
- San Juan Co: <http://www.sanjuanco.com/health/ehswater.aspx>
- Skagit Co: <http://www.skagitcounty.net/drinkingwater> or 360-336-9380
- Snohomish Co: 425-339-5250
- Whatcom Co: http://www.co.whatcom.wa.us/health/environmental/drinking_water/index.jsp
- WSDOH: <http://www.doh.wa.gov/ehp/dw/Programs/coliform.htm>

NOTES:
If the result is Unsatisfactory a repeat sample is required for Public Water Systems. Private individuals should investigate the cause of the unsatisfactory result and resample.
If E. Coli or Fecal Coliform are present in sample do not drink the water until it is properly treated.